

Michael Smit

Terry Sherring

s. 22 - employee numbers

Reasons or Causes that contributed to the event

A water leak from deck 6 to deck 5.

A small amount of loose friable amosite asbestos was discovered above both fan rooms, air samples confirm that there is not currently an airborne exposure issue, but friable material is required to be encapsulated or removed so it can not be disturbed.

Immediate actions taken to reduce or eliminate the hazard(s)

- Bulk sample taken for testing for ACM
- Area blocked off with tape/signage
- Fan room 4 and 5 locked out
- Possible ACM cleaned up according minor spill clean up work plan (filed in engine room)
- Arranged for air testing of crew area, which will be completed on the 16th of August (later this afternoon)
- Conducted a crew meeting regarding the possible ACM

Risk Level AFTER immediate actions taken

Assess the current risk level AFTER the immediate actions listed above have been taken to reduce the risk

Risk Level	Risk Acceptability
<input type="checkbox"/> 1 – 4 Low	Acceptable with Periodic Review
<input checked="" type="checkbox"/> 5 – 9 Medium	Tolerable with Periodic Review
<input type="checkbox"/> 10 – 12 High	Tolerable with Continuous Review
<input type="checkbox"/> 15 – 25 Extreme	Intolerable – Discontinue Exposure

Follow-on Actions (Risk Controls)

When air sample and bulk sample both are NON-ACM then the area will be cleared for normal use.
 When this is not the case and the air and/or bulk sample has ACM then the area will need to be cleaned by a BCFerries approved asbestos cleaning company until the area is cleared for normal use.

***Update: air samples taken from aft lounge area came back <0.01 fibers/ml (the treshold limit is 0.2 fibers/ml)

Review abatement records and the insulation report to determine if further sampling needs to be carried out to identify the source of the material
Inspect similar out of view machinery spaces for remnant materials

Name of Worksite Manager releasing the IAR for review Marcel van den Berg () s. 22 - employee number

~~Comments on when completed, by whom, and any other relevant information~~

Employee number Employee job position

Was worker attended to by OFA? Yes No Unknown

October 22, 2013

Deleted: October 16, 2013

Deleted: October 9, 2013

Was worker referred to off site medical aid?	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Unknown
Will worker miss work beyond date of injury?	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> Unknown
Employer Representative	Emp No.		
Worker Representative	Emp No.		

October 22, 2013

Deleted: October 15, 2013

Deleted: October 9, 2013